



AVOCA

17 Oliver St. #29 ♦ PO Box G ♦ Avoca, NY 14809

Central School District



Stephen Saxton, Superintendent
Steven Denaker, High School Principal
Stephanie Helgeland, Elementary Principal
Phone: 607-566-3000
Fax: 607-566-2398



April 1, 2020

Dear Avoca Central School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our school community, Avoca School District tests our schools' drinking water for lead. We have been proactive over the last two years changing out many of our old drinking fountains with new ones to ensure our water is safe.

Why Test School Drinking Water for Lead?

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years old. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and interfere with school performance. At very high levels, lead can even cause brain damage.

To protect public health, the U.S. Environmental Protection Agency (EPA) suggests that schools and daycare facilities test their drinking water for lead and take action if levels are at or over 20 parts per-billion (ppb). In NYS regulations were enacted to require testing of drinking water for lead at a more stringent level of 15 parts per-billion (ppb). If lead is found at any water outlet at levels above 15 parts per-billion (ppb), the NYS Department of Health and Education departments require taking action to reduce the lead.

Is Our School's Drinking Water Safe?

Yes, our schools' water is 100% safe. Avoca School District tested our drinking water for lead. All of the 63 water outlet samples we tested 0 showed lead levels above the 15 ppb mark.

How Can I Learn More?

You can see a copy of all of our water testing results at the Superintendent's office, which is open Monday to Friday from 7:30 a.m. to 4:00 p.m. and on our website at www.avocacsd.org. For more information about water quality in our school, please contact Michael Oyer at 607-566-3000 ext. 1126. For information about water quality and sampling for lead at home, contact your local water supplier or state drinking water agency.

Respectfully,

Superintendent



Life Science Laboratories, Inc.

Avoca Central School
Oliver St.
P.O. Box G
Avoca, NY 14809

Phone: (607) 566-2221
FAX: (607) 566-2398

Laboratory Analysis Report

Prepared For

Avoca Central School

LSL Project ID: 2001443

Receive Date/Time: 01/30/20 9:30

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248


LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box
424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:


Kristin E. Carpenter, Quality Staff

Date:

02/27/20

-- - LABORATORY ANALYSIS REPORT - -

Avoca Central School Avoca, NY

Sample ID: Avoca Central School **LSL Sample ID:** 2001443-001
Location: Lead Study (Main School Building K-12)
Sampled: 01/30/20 6:05 **Sampled By:** MM
Sample Matrix: PWS

Analytical Method	Prep Method	Prep	Analysis	Analyst
Analyte	Result Units	Date	Date & Time	Initials

(1) Lead Study

Number of Samples

65

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-001

Lab ID: 2001443-001A
Collection Date: 01/30/20 6:05
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 16:45

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-002**Lab ID:** 2001443-002A**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 16:51

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-003**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-003A**Matrix:** PWS**Collection Date:** 01/30/20 6:05**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 16:53

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-004**Lab ID:** 2001443-004A**Collection Date:** 01/30/20 6:05**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 16:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-005**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-005A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0020	mg/L	02/19/20 16:56

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-006**Lab ID:** 2001443-006A**Collection Date:** 01/30/20 6:05**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 16:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-007**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-007A**Matrix:** PWS**Collection Date:** 01/30/20 6:30**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:00

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-008**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-008A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-009

Lab ID: 2001443-009A
Collection Date: 01/30/20 6:05
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:08

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0010**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-010A**Matrix:** PWS**Collection Date:** 01/30/20 6:25**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0011**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-011A**Matrix:** PWS**Collection Date:** 01/30/20 6:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0012	mg/L	02/19/20 17:12

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0012**Lab ID:** 2001443-012A**Collection Date:** 01/30/20 6:05**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:14

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0013**Lab ID:** 2001443-013A**Collection Date:** 01/30/20 6:05**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	02/19/20 17:15

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0014**Lab ID:** 2001443-014A**Collection Date:** 01/30/20 6:07**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:17

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0015**Lab ID:** 2001443-015A**Collection Date:** 01/30/20 6:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0016**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-016A**Matrix:** PWS**Collection Date:** 01/30/20 6:30**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0086	mg/L	02/19/20 17:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0017**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-017A**Matrix:** PWS**Collection Date:** 01/30/20 6:30**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:23

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0018**Lab ID:** 2001443-018A**Collection Date:** 01/30/20 6:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0019**Lab ID:** 2001443-019A**Collection Date:** 01/30/20 7:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0020

Lab ID: 2001443-020A
Collection Date: 01/30/20 6:30
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:33

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0021**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-021A**Matrix:** PWS**Collection Date:** 01/30/20 6:25**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:34

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0022**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-022A**Matrix:** PWS**Collection Date:** 01/30/20 6:25**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0023**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-023A**Matrix:** PWS**Collection Date:** 01/30/20 6:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:42

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0024**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-024A**Matrix:** PWS**Collection Date:** 01/30/20 6:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:44

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0025**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-025A**Matrix:** PWS**Collection Date:** 01/30/20 6:35**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:50

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0026**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-026A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0018	mg/L	02/19/20 17:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0027**Lab ID:** 2001443-027A**Collection Date:** 01/30/20 6:23**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 17:53

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0028**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-028A**Matrix:** PWS**Collection Date:** 01/30/20 7:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:04

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0029**Lab ID:** 2001443-029A**Collection Date:** 01/30/20 6:24**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0030

Lab ID: 2001443-030A
Collection Date: 01/30/20 7:20
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:08

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0031**Lab ID:** 2001443-031A**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:12

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0032**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-032A**Matrix:** PWS**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:16

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0033**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-033A**Matrix:** PWS**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0016	mg/L	02/19/20 18:18

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0034**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-034A**Matrix:** PWS**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0035**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-035A**Matrix:** PWS**Collection Date:** 01/30/20 6:55**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0012	mg/L	02/19/20 18:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0036**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Lab ID:** 2001443-036A**Collection Date:** 01/30/20 6:50**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0037**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-037A**Matrix:** PWS**Collection Date:** 01/30/20 6:40**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:29

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0038**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-038A**Matrix:** PWS**Collection Date:** 01/30/20 6:50**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0018	mg/L	02/19/20 18:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0039**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-039A**Matrix:** PWS**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:33

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0040**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-040A**Matrix:** PWS**Collection Date:** 01/30/20 6:45**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0041

Lab ID: 2001443-041A
Collection Date: 01/30/20 6:40
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0042**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-042A**Matrix:** PWS**Collection Date:** 01/30/20 7:10**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:42

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0043**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-043A**Matrix:** PWS**Collection Date:** 01/30/20 7:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:48

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0044**Lab ID:** 2001443-044A**Collection Date:** 01/30/20 7:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:50

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: ACS-0045

Project: Avoca Central School

Location: Lead Study (Main School Building K-12)

Lab ID: 2001443-045A

Matrix: PWS

Collection Date: 01/30/20 7:00

Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0046**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-046A**Matrix:** PWS**Collection Date:** 01/30/20 7:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:54

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0047

Lab ID: 2001443-047A
Collection Date: 01/30/20 6:35
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:56

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0048**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-048A**Matrix:** PWS**Collection Date:** 01/30/20 7:12**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 18:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0049**Lab ID:** 2001443-049A**Collection Date:** 01/30/20 7:12**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:00

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0050**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-050A**Matrix:** PWS**Collection Date:** 01/30/20 7:10**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School
Location: Lead Study (Main School Building K-12)
Matrix: PWS

Client Sample ID: ACS-0051

Lab ID: 2001443-051A
Collection Date: 01/30/20 7:05
Date Received: 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:03

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0052**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-052A**Matrix:** PWS**Collection Date:** 01/30/20 7:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:05

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0053**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-053A**Matrix:** PWS**Collection Date:** 01/30/20 7:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:11

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0054**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-054A**Matrix:** PWS**Collection Date:** 01/30/20 7:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:13

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Matrix:** PWS**Client Sample ID:** ACS-0055**Lab ID:** 2001443-055A**Collection Date:** 01/30/20 6:35**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:15

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0056**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-056A**Matrix:** PWS**Collection Date:** 01/30/20 7:15**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:17

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0057**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-057A**Matrix:** PWS**Collection Date:** 01/30/20 6:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0058**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-058A**Matrix:** PWS**Collection Date:** 01/30/20 7:20**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0059**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-059A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:22

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0060**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-060A**Matrix:** PWS**Collection Date:** 01/30/20 6:23**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0061**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-061A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	02/19/20 19:26

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0063**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-063A**Matrix:** PWS**Collection Date:** 01/30/20 6:50**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	02/19/20 19:36

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0064**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-064A**Matrix:** PWS**Collection Date:** 01/30/20 6:40**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:38

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0065**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-065A**Matrix:** PWS**Collection Date:** 01/30/20 6:55**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** ACS-0066**Project:** Avoca Central School**Location:** Lead Study (Main School Building K-12)**Lab ID:** 2001443-066A**Matrix:** PWS**Collection Date:** 01/30/20 6:00**Date Received:** 01/30/20 9:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/19/20 19:42

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

Invoiced_Gov_FLL

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

bowenc@lsl-inc.com

Report Address:
Name: Avoca Central School
Company: P.O. Box G
Street: Olive St.
City/State: Avoca, NY Zip: 14809
Phone: 607-566-2221
Fax: 607-566-2398
email: 552xtone@avocacsd.org

Billing or Copy to Information (if applicable):
Name:
Company:
Street: SAME
City/State/Zip:
Phone:
Fax:
email:

Turn Around Time For Report			
Standard	RUSH: Pre-Authorization Required		
14 DAY	Next Day*	3-Day*	*Additional charges apply to all RUSH turnaround times
<input checked="" type="checkbox"/>	2-Day*	7-Day*	
Date Needed or Special Instructions: <u>Please e-mail 126 reports to school district and mullen@stbcs.org and FAX to NYSDOH (Hornell)</u>			
Authorization or P.O. #			

Client Project ID/Client Site ID Main School Building K-12

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
Elem off. Fountain	1/30/20	6:05 Am	Grab	PWS	HNO3	1	p250ml	Lead	<2	001A
Kitchen hand sink #2		6:00 Am							<2	002A
H.S. OFF. restroom		6:05 Am							<2	003A
Fountain guidance		6:05 Am							<2	004A
Kitchen restroom		6:00 Am						Samples Preserved Upon Receipt at Lab	<2	005A
Elem off restroom		6:05 Am							<2	006A
Fountain nurse's		6:30 Am							<2	007A
Cafe Fountain		6:00 Am							<2	008A
Elem office sink		6:05 Am							<2	009A
Rm 103 sink		6:25 Am							<2	010A

LSL use only:	Custody Transfers		Date	Time
	Sampled By: <u>Maurice Mullen</u>	Received By:		
	Relinquished By: <u>Maurice Mullen</u>	Received By:		
	Relinquished By:	Received for Lab By: <u>James Shuler</u>	1/30/20	9:30
	Shipment Method:	Received Intact: Y N	Sample Temp: <u>15.9°</u>	

Containers this C-O-C (10)

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Invoiced_Gov_FLL

bowenc@lsl-inc.com

Report Address:						Billing or Copy to Information (if applicable):						Turn Around Time For Report					
Name: <u>Avoca Central School</u>						Name:						Standard		RUSH: Pre-Authorization Required		*Additional charges apply to all RUSH turnaround times	
Company: <u>P.O. Box G</u>						Company:						14 DAY		Next Day* <input type="checkbox"/> 3-Day* <input type="checkbox"/>			
Street: <u>Oliver St.</u>						Street: <u>SAME</u>						<input checked="" type="checkbox"/>		2-Day* <input type="checkbox"/> 7-Day* <input type="checkbox"/>			
City/State: <u>Avoca, NY</u> Zip: <u>14809</u>						City/State/Zip:						Date Needed or Special Instructions: <u>Please e-mail 126 reports to school district and mullen@gsboces.org and FAX to NYSDOH (Hornell)</u>					
Phone: <u>607-566-2221</u>						Phone:											
Fax: <u>607-566-2398</u>						Fax:						Authorization or P.O. #					
email: <u>ss@extel-avoca.nysd.net</u>						email:						ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.					
Client Project ID/Client Site ID						Main School Building K-12											
Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#							
						#	size/type										
<u>Super. rest room</u>	<u>1/30/20</u>	<u>6:15 Am</u>	<u>Grab</u>	<u>PWS</u>	<u>HNO3</u>	<u>1</u>	<u>p250ml</u>	<u>Lead</u>	<u><2</u>	<u>011A</u>							
<u>H.S. Office</u>		<u>6:05 Am</u>							<u><2</u>	<u>012A</u>							
<u>Rm 107 sink</u>		<u>6:05 Am</u>							<u><2</u>	<u>013A</u>							
<u>Rm 109 sink</u>		<u>6:07 Am</u>							<u><2</u>	<u>014A</u>							
<u>Rm 108 sink</u>		<u>6:15 Am</u>							<u><2</u>	<u>015A</u>							
<u>nurse's med. room</u>		<u>6:30 Am</u>						<u>Samples Preserved Upon Receipt at Lab</u>	<u><2</u>	<u>016A</u>							
<u>nurse's off. sink</u>		<u>6:30 Am</u>							<u><2</u>	<u>017A</u>							
<u>Rm 100 sink</u>		<u>6:15 Am</u>							<u><2</u>	<u>018A</u>							
<u>Rm 203 rest room</u>		<u>7:15 Am</u>							<u><2</u>	<u>019A</u>							
<u>Art Room #1</u>		<u>6:30 Am</u>							<u><2</u>	<u>020A</u>							
LSL use only:						Custody Transfers						Date		Time			
Samples Preserved						Sampled By: <u>MOUNCE Mullen</u>						Received By:					
Upon Receipt at Lab						Relinquished By: <u>MOUNCE Mullen</u>						Received By:					
Containers this C-O-C <u>(10)</u>						Relinquished By:						Received for Lab By: <u>Jessica Shisig</u>		<u>1/30/20</u> <u>9:30</u>			
						Shipment Method:						Received Intact: <u>Y N</u>		Sample Temp: <u>15.9</u>			

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

Invoiced_Gov_FLL

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

bowenc@lsl-inc.com

Report Address:
Name: Avoca Central School
Company: P.O. Box C
Street: Oliver St.
City/State: Avoca, NY Zip: 14809
Phone: 607-566-2221
Fax: 607-566-2398
email: ss@extone-avocacsd.org

Billing or Copy to Information (if applicable):
Name:
Company:
Street: SAME
City/State/Zip:
Phone:
Fax:
email:

Turn Around Time For Report			
Standard	RUSH: Pre-Authorization Required		
14 DAY	Next Day*	3-Day*	*Additional charges apply to all RUSH turnaround times
<input checked="" type="checkbox"/>	2-Day*	7-Day*	
Date Needed or Special Instructions: <u>Please e-mail 125 reports to school district and m.mullen@extone.org and FAX to NYSDOH (Normell)</u>			
Authorization or P.O. #			
ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.			

Client Project ID/Client Site ID

Main School Building K-12

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
<u>Nurse's restroom</u>	<u>1/30/20</u>	<u>6:25 Am</u>	<u>Grab</u>	<u>PWS</u>	<u>HNO3</u>	<u>1</u>	<u>p250ml</u>	<u>Lead</u>	<u><2</u>	<u>021A</u>
<u>Rm 100 restroom</u>		<u>6:25 Am</u>							<u><2</u>	<u>022A</u>
<u>Rm 106 restroom</u>		<u>6:20 Am</u>							<u><2</u>	<u>023A</u>
<u>Rm 107</u>		<u>6:15 Am</u>							<u><2</u>	<u>024A</u>
<u>Aud. lobby men's</u>		<u>6:35 Am</u>							<u><2</u>	<u>025A</u>
<u>Kitchen hand sink</u>		<u>6:00 Am</u>							<u><2</u>	<u>026A</u>
<u>Rm 103 restroom</u>		<u>6:23 Am</u>							<u><2</u>	<u>027A</u>
<u>Rm 203 Fountain</u>		<u>7:15 Am</u>							<u><2</u>	<u>028A</u>
<u>Rm 103 Fountain</u>		<u>6:24 Am</u>							<u><2</u>	<u>029A</u>
<u>Rm 204 sink</u>		<u>7:20 am</u>							<u><2</u>	<u>030A</u>

LSL use only:
Samples Preserved
Upon Receipt at Lab

Containers this C-O-C

(10)

Custody Transfers

Sampled By: Maurice Mullen
Relinquished By: Maurice Mullen
Relinquished By:
Shipment Method:

Received By:
Received By:
Received for Lab By: John Givens
Received Intact: Y N

Sample Temp: 15.9

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

Invoiced_Gov_FLL

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

bowenc@lsl-inc.com

Report Address:		Billing or Copy to Information (if applicable):		Turn Around Time For Report							
Name:		Name:		Standard		RUSH: Pre-Authorization Required		*Additional charges apply to all RUSH turnaround times			
Company:		Company:		14 DAY		Next Day*		3-Day*			
Street:		Street:		<input checked="" type="checkbox"/>		2-Day*		7-Day*			
City/State:		City/State/Zip:		Date Needed or Special Instructions: Please e-mail 126 reports to school district and m.mullen@nysdotc.com and FAX to NYSDOTC (Hornell)							
Phone:		Phone:		Authorization or P.O. #							
Fax:		Fax:		ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.							
email:		email:									
Client Project ID/Client Site ID											
Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#	
						#	size/type				
Rm 138 sink #2	1/30/00	6:45 Am	Grab	PWS	HNO3	1	p250ml	Lead	<2	631A	
Rm 138 sink #1		6:45 Am							<2	632A	
Rm 140 sink		6:45 Am							<2	633A	
Rm 140 white sink		6:45 Am							<2	634A	
girls rm locker room		6:55 Am							<2	635A	
official ice maker		6:50 Am							<2	636A	
Aud fountain #1		6:40 Am							<2	637A	
girls coach		6:50 Am							<2	638A	
sports end boys		6:45 Am							<2	639A	
sports end fountain		6:45 Am							<2	640A	
LSL use only:				Custody Transfers							
Samples Preserved				Sampled By: MAURICE MULLEN				Received By:			
Upon Receipt at Lab				Relinquished By: MAURICE MULLEN				Received By:			
Containers this C-O-C (10)				Relinquished By:				Received for Lab By: JIM SHIRK			
				Shipment Method:				Received Intact: Y N			
								Date			
								Time			
								Sample Temp: 15.9			

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

Invoiced_Gov_FLL

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

bowenc@lsl-inc.com

Report Address:
Name: Avoca Central School
Company: P.O. Box G
Street: Oliver St.
City/State: Avoca, NY Zip: 14809
Phone: 607-566-2221
Fax: 607-566-2398
email: ssextone@avocasd.org

Billing or Copy to Information (if applicable):
Name:
Company:
Street: SAME
City/State/Zip:
Phone:
Fax:
email:

Turn Around Time For Report			
Standard	RUSH: Pre-Authorization Required		
14 DAY	Next Day*	3-Day *	*Additional charges apply to all RUSH turnaround times
<input checked="" type="checkbox"/>	2-Day *	7-Day *	

Date Needed or Special Instructions: Please e-mail 126 reports to school district and mmullen@gs+boces.org and FAX to NYSDOH (Hornell)

Authorization or P.O. #

Client Project ID/Client Site ID

Main School Building K-12

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
<u>1st Fountain #2</u>	<u>1/30/20</u>	<u>6:40 Am</u>	<u>Grab</u>	<u>PWS</u>	<u>HNO3</u>	<u>1</u>	<u>p250ml</u>	<u>Lead</u>	<u><2</u>	<u>041A</u>
<u>Rm 223 Fountain</u>		<u>7:10 Am</u>							<u><2</u>	<u>042A</u>
<u>2nd Floor Fountain Z16</u>		<u>7:5 Am</u>							<u><2</u>	<u>043A</u>
<u>Rm 216 restroom</u>		<u>7:00 Am</u>							<u><2</u>	<u>044A</u>
<u>Rm 216 sink #1</u>		<u>7:00 Am</u>							<u><2</u>	<u>045A</u>
<u>Rm 216 sink #2</u>		<u>7:00 Am</u>							<u><2</u>	<u>046A</u>
<u>Art room #2</u>		<u>6:35 Am</u>							<u><2</u>	<u>047A</u>
<u>Rm 206 Faculty</u>		<u>7:12 Am</u>							<u><2</u>	<u>048A</u>
<u>Rm 209 restroom</u>		<u>7:12 Am</u>							<u><2</u>	<u>049A</u>
<u>Library restroom</u>	<u>✓</u>	<u>7:14 Am</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u><2</u>	<u>050A</u>

LSL use only:

Samples Preserved

Upon Receipt at Lab

Containers this C-O-C (0)

Custody Transfers

Sampled By: Maurice Mullen

Relinquished By: Maurice Mullen

Relinquished By:

Shipment Method:

Received By:

Received By:

Received for Lab By: Jane Sherry

Received Intact: Y N

Date Time

1/30/20 9:36

Sample Temp: 15.9

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Invoiced_Gov_FLL

bowenc@lsl-inc.com

Report Address:
Name: Avoca Central School
Company: P.O. Box G
Street: Oliver St.
City/State: Avoca, NY Zip: 14809
Phone: 607-566-2221
Fax: 607-566-2398
email: ssextone@avoccsd.org

Billing or Copy to Information (if applicable):
Name: _____
Company: _____
Street: SAME
City/State/Zip: _____
Phone: _____
Fax: _____
email: _____

Turn Around Time For Report			
Standard	RUSH: Pre-Authorization Required		
14 DAY	Next Day* <input type="checkbox"/>	3-Day* <input type="checkbox"/>	*Additional charges apply to all RUSH turnaround times
<input checked="" type="checkbox"/>	2-Day* <input type="checkbox"/>	7-Day* <input type="checkbox"/>	
Date Needed or Special Instructions: <u>Please e-mail 126 reports to school district and mullen@sgs-boces.org and FAX to NYSDOH (Honnell)</u>			
Authorization or P.O. #			

Client Project ID/Client Site ID Main School Building K-12

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
W.S. 2nd Fl Fountain	1/30/20	7:05 AM	Grab	PWS	HNO3	1	p250ml	Lead	42	0517A
Rm 202 sink		7:20 AM							42	0527A
Rm 200 sink		7:20 AM							42	0533A
Rm 201 sink		7:20 AM							42	0549A
Aud Women #1		6:30 AM							42	0555A
Rm 203 sink		7:15 AM							42	0566A
Rm 104 Fountain		6:20 AM							42	0572A
Rm 205 sink		7:20 AM							42	0580A
Kitchen ice maker		6:00 PM							42	0594A
Rm 105 restroom		12:30 AM							42	0609A

LSL use only:	Custody Transfers		Date	Time
Samples Preserved	Sampled By: <u>Maurice Mullen</u>	Received By:		
Upon Receipt at Lab	Relinquished By: <u>Maurice Mullen</u>	Received By:		
Containers this C-O-C (10)	Relinquished By:	Received for Lab By: <u>J. J. Shire</u>	1/30/20	9:30
	Shipment Method:	Received Intact: <u>Y N</u>	Sample Temp: <u>15.9</u>	

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2001443

Invoice_Gov_FLL

200

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-213-4090
f) 585-213-4192

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-213-4090
f) 585-213-4192

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

bowenc@lsl-inc.com

Turn Around Time For Report

Report Address: Name: <u>Avoca Central School</u> Company: <u>P.O. Box G</u> Street: <u>Oliver St.</u> City/State: <u>Avoca, NY</u> Zip: <u>14809</u> Phone: <u>607-566-2221</u> Fax: <u>607-566-2398</u> email: <u>ss@avoca-ny.org</u>		Billing or Copy to Information (if applicable): Name: Company: Street: <u>SAME</u> City/State/Zip: Phone: Fax: email:		Standard 14 DAY <input checked="" type="checkbox"/> RUSH: Pre-Authorization Required Next Day* <input type="checkbox"/> 3-Day* <input type="checkbox"/> 2-Day* <input type="checkbox"/> 7-Day* <input type="checkbox"/> Date Needed or Special Instructions: <u>Please e-mail 126 reports to school district and mmullen@gsboces.org and FAX to NYSDOH (Noone II)</u> Authorization or P.O. # ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.	
Client Project ID/Client Site ID <u>Main School Building K-12</u>					

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
<u>Prep Sink c2fc</u>	<u>1/30/00</u>	<u>6:00 AM</u>	<u>Grab</u>	<u>PWS</u>	<u>HNO3</u>	<u>1</u>	<u>p250ml</u>	<u>Lead</u>	<u>C2</u>	<u>067A</u>
<u>* Aud. fountain #2</u>		<u>6:19 AM</u>							<u>C2</u>	<u>062A</u>
<u>Boys Corb</u>		<u>6:50 AM</u>							<u>C2</u>	<u>063A</u>
<u>Aud. women's #2</u>		<u>6:40 AM</u>							<u>C2</u>	<u>064A</u>
<u>2nd Floor Faculty</u>		<u>6:55 AM</u>							<u>C2</u>	<u>065A</u>
<u>Official Sink</u>		<u>6:00 AM</u>							<u>C2</u>	<u>066A</u>
<u>* Sample not received - ins</u>										

LSL use only: Samples Preserved Upon Receipt at Lab Containers this C-O-C <u>(6)</u>	Custody Transfers		Date	Time
	Sampled By: <u>Maurice Mullen</u>		Received By:	
	Relinquished By: <u>Maurice Mullen</u>		Received By:	
	Relinquished By:		Received for Lab By: <u>Jordan Spiller</u>	<u>1/30/00</u>
Shipment Method:		Received Intact: <u>Y N</u>	Sample Temp: <u>15.9</u>	

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-213-4090 for more info.