



AVOCA

17 Oliver St. #29 ♦ PO Box G ♦ Avoca, NY 14809



Central School District



Stephen Saxton, Superintendent
Scott Carroll, Middle/High School Principal
Deanna Wilkinson, Elementary Principal
Phone: 607-566-3000
Fax: 607-566-2398

September 22, 2023

Dear Avoca Central School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our school community, Avoca School District tests our schools' drinking water for lead. We have been proactive over the last two years changing out many of our old drinking fountains with new ones to ensure our water is safe.

Why Test School Drinking Water for Lead?

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years old. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and interfere with school performance. At very high levels, lead can even cause brain damage.

To protect public health, the U.S. Environmental Protection Agency (EPA) suggests that schools and daycare facilities test their drinking water for lead and take action if levels are at or over 20 parts per-billion (ppb). In NYS, regulations were enacted to require testing of drinking water for lead at a more stringent level of 5 parts per-billion (ppb). If lead is found at any water outlet at levels above 5 parts per-billion (ppb), the NYS Department of Health and Education departments require taking action to reduce the lead level.

Is Our School's Drinking Water Safe?

Yes, our schools' water is 100% safe. Avoca School District tested our drinking water for lead. Of the 98 water outlet samples we tested 2 showed lead levels above the 5 ppb mark. On one of those outlets the fixture was replaced and upon retesting the water was found to be under the 5 ppb threshold. On the other outlet we have taken the outlet out of service and it won't be used for drinking purposes.

How Can I Learn More?

You can see a copy of all of our water testing results at the Superintendent's office, which is open Monday to Friday from 7:30 a.m. to 4:00 p.m. and on our website at [www. Avocacsd.org](http://www.Avocacsd.org) under Resources. For more information about water quality in our school, please contact Robert Hyer at 607-566-3000 ext. 1126. For information about water quality and sampling for lead at home, contact your local water supplier or state drinking water agency.

Respectfully,

Superintendent



Life Science Laboratories, Inc.

Avoca Central School District
17-29 Oliver St.
Avoca, NY 14809

Phone: (607) 522-2221
FAX: (607) 522-2398

Laboratory Analysis Report Prepared For Avoca Central School District

LSL Project ID: 2307183

Receive Date/Time: 05/24/23 10:12

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:

David J. Prichard, Director of Tech. Services

Date: 6/28/23

A copy of this report was sent to:

moyer@gstboces.com
Hornell DOH

- - LABORATORY ANALYSIS REPORT - -

Avoca Central School District Avoca, NY

Sample ID: Avoca Central School District LSL Sample ID: 2307183-001
Location: Lead Study
Sampled: 05/24/23 5:45 Sampled By: MO
Sample Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
(1) EPA 200.8, Rev. 5.4 Metals	EPA 200.2			
Please refer to the next page	98			MT

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab

rptC001

Life Science Laboratories, Inc.

Page 2 of 2
Date Printed: 6/26/23

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: *1 Bag Filter POE*

Lab ID: 2307183-001A
Collection Date: 05/24/23 5:45
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011 *	mg/L	06/14/23 17:09

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 2 Elm Office Sink

Lab ID: 2307183-002A
Collection Date: 05/24/23 5:47
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:20

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 3 Elm Office Restroom

Lab ID: 2307183-003A
Collection Date: 05/24/23 5:48
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Project:** Avoca Central School District**Location:****Matrix:** PWS**Client Sample ID:** 4 Elm Office Drink Fountain**Lab ID:** 2307183-004A**Collection Date:** 05/24/23 5:49**Date Received:** 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 5 HS Office Restroom

Lab ID: 2307183-005A
Collection Date: 05/24/23 5:51
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:38

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 6 HS Office Sink

Lab ID: 2307183-006A
Collection Date: 05/24/23 5:52
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 7 HS Bottle Filler

Lab ID: 2307183-007A
Collection Date: 05/24/23 5:53
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:45

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 8 Cafeteria Restroom 1

Lab ID: 2307183-008A
Collection Date: 05/24/23 5:55
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:48

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 9 Cafeteria Restroom 2

Lab ID: 2307183-009A
Collection Date: 05/24/23 5:56
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 10 Cafeteria Bottle Filler

Lab ID: 2307183-010A
Collection Date: 05/24/23 5:57
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 11 Cafeteria Drink Fountain

Lab ID: 2307183-011A
Collection Date: 05/24/23 5:57
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 17:59

Qualifiers:

* Value may exceed the Acceptable Level	B Analyte detected in the associated Method Blank
E Value exceeds the instrument calibration range	H Holding times for preparation or analysis exceeded
J Analyte detected below the PQL	ND Not Detected at the Practical Quantitation Limit (PQL)
P Prim./Conf. column %D or RPD exceeds limit	S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 12 Commons Hall Restroom

Lab ID: 2307183-012A
Collection Date: 05/24/23 6:00
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/14/23 18:02

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:31

Page 12 of 98

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 13 Serving Area Sink

Lab ID: 2307183-013A
Collection Date: 05/24/23 6:01
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 18:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 14 Washroom Sink 1

Lab ID: 2307183-014A
Collection Date: 05/24/23 6:01
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0020	mg/L	06/14/23 18:09

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 15 Washroom Sink 2

Lab ID: 2307183-015A
Collection Date: 05/24/23 6:02
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/14/23 18:20

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:31



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 16 Washroom Hand Sink

Lab ID: 2307183-016A
Collection Date: 05/24/23 6:02
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 18:24

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 17 Washroom Prerinse

Lab ID: 2307183-017A
Collection Date: 05/24/23 6:03
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0021	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/14/23 18:27

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 18 Kitchen Ice Maker

Lab ID: 2307183-018A
Collection Date: 05/24/23 6:03
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 18:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 149 Kitchen Prep Sink

Lab ID: 2307183-019A
Collection Date: 05/24/23 6:04
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 18:34

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 20 Kitchen Skillet Filler

Lab ID: 2307183-020A
Collection Date: 05/24/23 6:04
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0032	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/14/23 18:38

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:31



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 21 Kitchen Restroom

Lab ID: 2307183-021A

Collection Date: 05/24/23 6:12

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/14/23 18:41

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:31

Page 21 of 98



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 22 Kitchen Hand Sink

Lab ID: 2307183-022A
Collection Date: 05/24/23 6:13
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 18:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 23 *Small Gym Fountain*

Lab ID: 2307183-023A

Collection Date: 05/24/23 6:15

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:02

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 24 Staff Room Sink 1

Lab ID: 2307183-024A
Collection Date: 05/24/23 6:16
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 25 Staff Room Sink 2

Lab ID: 2307183-025A
Collection Date: 05/24/23 6:16
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	mg/L	06/14/23 19:10

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- NID Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 26 Staff Room Restroom

Lab ID: 2307183-026A
Collection Date: 05/24/23 6:17
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	< 0.0010	mg/L	06/14/23 19:13

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 27 132 Sink 1

Lab ID: 2307183-027A
Collection Date: 05/24/23 6:19
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:17

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 28 132 Sink 2

Lab ID: 2307183-028A
Collection Date: 05/24/23 6:19
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:20

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 29 Aud Lobby Fountain 1

Lab ID: 2307183-029A
Collection Date: 05/24/23 6:23
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:24

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 30 Aud Lobby Fountain2

Lab ID: 2307183-030A
Collection Date: 05/24/23 6:23
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: *31 Aud Lobby Mr r Sink*

Lab ID: 2307183-031A
Collection Date: 05/24/23 6:24
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	0.0020	mg/L	06/14/23 19:31

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LJMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 32 Aud Lobby Frr Sink 1

Lab ID: 2307183-032A
Collection Date: 05/24/23 6:25
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/14/23 19:34

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf' column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 33 Aud Lobby Frr Sink 2

Lab ID: 2307183-033A
Collection Date: 05/24/23 6:25
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 11:50

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 34 Men PE Restroom

Lab ID: 2307183-034A
Collection Date: 05/24/23 6:30
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	0.0036	mg/L	06/16/23 11:53

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 35 Official Room Sink

Lab ID: 2307183-035A
Collection Date: 05/24/23 6:30
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0042	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 11:57

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 36 Official Room Ice Maker

Lab ID: 2307183-036A
Collection Date: 05/24/23 6:31
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 12:00

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 37 Female PE Restroom

Lab ID: 2307183-037A
Collection Date: 05/24/23 6:32
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	0.0037	mg/L	06/16/23 12:04

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 38 AG Hall Boy Restroom

Lab ID: 2307183-038A
Collection Date: 05/24/23 6:37
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:07

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 39 AG Hall Boy Restroom

Lab ID: 2307183-039A
Collection Date: 05/24/23 6:36
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:11

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 39 AG Hall Girl Restroom

Lab ID: 2307183-040A
Collection Date: 05/24/23 6:36
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 12:14

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim /Conf column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 41 142 Sink 1

Lab ID: 2307183-041A
Collection Date: 05/24/23 6:42
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 12:18

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:32

Page 41 of 98



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 42 142 Sink 2

Project: Avoca Central School District

Location:

Lab ID: 2307183-042A

Matrix: PWS

Collection Date: 05/24/23 6:42

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 43 138 Sink 1

Lab ID: 2307183-043A
Collection Date: 05/24/23 6:45
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:39

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- NID Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 44 138 Sink 2

Lab ID: 2307183-044A
Collection Date: 05/24/23 6:45
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:43

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 45 126 Restroom

Lab ID: 2307183-045A
Collection Date: 05/24/23 6:50
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 12:46

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 46 124 Sink

Lab ID: 2307183-046A
Collection Date: 05/24/23 6:51
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 12:50

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LJMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 47 124 Ice Maker

Lab ID: 2307183-047A
Collection Date: 05/24/23 6:52
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev.5.4	(EPA 200.2)
Lead	0.0019	mg/L	06/16/23 12:53

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 48 122 Sink

Lab ID: 2307183-048A
Collection Date: 05/24/23 6:52
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	< 0.0010	mg/L	06/16/23 12:57

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Project: Avoca Central School District

Location:

Matrix: PWS

Client Sample ID: 49 124 Restroom

Lab ID: 2307183-049A

Collection Date: 05/24/23 6:53

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0032	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 13:00

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:32

Page 49 of 98



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 50 112 Restroom

Lab ID: 2307183-050A
Collection Date: 05/24/23 6:54
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 13:11

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 51 106 Restroom

Lab ID: 2307183-051A
Collection Date: 05/24/23 6:57
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0051 *	mg/L	06/16/23 13:14

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 52 106 Sink

Lab ID: 2307183-052A
Collection Date: 05/24/23 6:57
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/16/23 13:18

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 53 105 Restroom

Lab ID: 2307183-053A
Collection Date: 05/24/23 6:58
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 13:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 54 105 Sink

Lab ID: 2307183-054A
Collection Date: 05/24/23 6:58
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 13:25

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 55 102 Sink

Lab ID: 2307183-055A
Collection Date: 05/24/23 7:00
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4 (EPA 200.2)	
Lead	< 0.0010	mg/L	06/16/23 13:28

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Print/Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 56 Elm Hall Bottle Filler

Lab ID: 2307183-056A
Collection Date: 05/24/23 7:01
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/16/23 13:32

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 57 103 Restroom

Lab ID: 2307183-057A
Collection Date: 05/24/23 7:01
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 13:35

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 58 103 Sink

Lab ID: 2307183-058A
Collection Date: 05/24/23 7:02
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4 (EPA 200.2)	
Lead	< 0.0010	mg/L	06/16/23 13:39

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 59 100 Restroom

Project: Avoca Central School District

Location:

Lab ID: 2307183-059A

Matrix: PWS

Collection Date: 05/24/23 7:10

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 14:16

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 60 100 Sink

Lab ID: 2307183-060A
Collection Date: 05/24/23 7:10
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 14:20

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 61 200 Sink

Lab ID: 2307183-061A
Collection Date: 05/24/23 7:22
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 14:23

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- NID Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 62 201 Sink

Lab ID: 2307183-062A
Collection Date: 05/24/23 7:23
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4 (EPA 200.2)	
Lead	< 0.0010	mg/L	06/16/23 14:34

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 63 202 Sink

Project: Avoca Central School District

Location:

Matrix: PWS

Lab ID: 2307183-063A

Collection Date: 05/24/23 7:24

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 14:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:33

Page 63 of 98



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 64 Elm 2nd Fl. Hall Bottle Fill

Lab ID: 2307183-064A
Collection Date: 05/24/23 7:24
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 14:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 65 203 Restroom

Lab ID: 2307183-065A
Collection Date: 05/24/23 7:25
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 14:44

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 66 203 Sink

Lab ID: 2307183-066A
Collection Date: 05/24/23 7:25
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 14:48

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Print/Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 67 204 Sink

Lab ID: 2307183-067A
Collection Date: 05/24/23 7:26
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 14:59

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 68 205 Sink

Project: Avoca Central School District

Location:

Lab ID: 2307183-068A

Matrix: PWS

Collection Date: 05/24/23 7:26

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:02

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 69 Elm Hall 2nd Staff RR

Lab ID: 2307183-069A
Collection Date: 05/24/23 7:27
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 70 Fountain Across RM 215

Lab ID: 2307183-070A
Collection Date: 05/24/23 7:28
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4 (EPA 200.2)	
Lead	0.0011	mg/L	06/16/23 15:09

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 71 217 Restroom

Lab ID: 2307183-071A
Collection Date: 05/24/23 7:27
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:13

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 72 Bottle Fill Next to 223

Lab ID: 2307183-072A
Collection Date: 05/24/23 7:35
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:16

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 73 Elevator Restroom

Lab ID: 2307183-073A
Collection Date: 05/24/23 7:36
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:20

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 74 Science Storage Tank

Lab ID: 2307183-074A
Collection Date: 05/24/23 7:38
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:23

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- NID Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LJMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 75 216 Restroom

Lab ID: 2307183-075A
Collection Date: 05/24/23 7:40
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:27

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 76 216 Sink 1

Lab ID: 2307183-076A
Collection Date: 05/24/23 7:40
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:30

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 77 216 Sink 2

Lab ID: 2307183-077A
Collection Date: 05/24/23 7:40
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 78 Fountain Next to 218

Lab ID: 2307183-078A
Collection Date: 05/24/23 7:42
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:44

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 79 Bottle Fill Next to 233

Lab ID: 2307183-079A
Collection Date: 05/24/23 7:45
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8, Rev. 5.4 mg/L	(EPA 200.2) 06/16/23 15:48

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

Print Date: 06/26/23 10:33

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 80 235 Sink

Project: Avoca Central School District**Location:**

Lab ID: 2307183-080A

Matrix: PWS

Collection Date: 05/24/23 7:47

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0011	mg/L	06/16/23 15:52

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 81 237 Sink 1

Lab ID: 2307183-081A
Collection Date: 05/24/23 7:49
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 15:55

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 82 237 Sink 2

Lab ID: 2307183-082A
Collection Date: 05/24/23 7:49
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:06

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 83 237 Kiln Sink

Lab ID: 2307183-083A
Collection Date: 05/24/23 7:49
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:09

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf' column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 84 241 Sink

Lab ID: 2307183-084A
Collection Date: 05/24/23 7:50
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:13

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 85 Bottle Fill Next to 249

Lab ID: 2307183-085A
Collection Date: 05/24/23 7:52
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:47

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 86 Concession Stand

Lab ID: 2307183-086A
Collection Date: 05/24/23 8:21
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:51

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: 87 Toilet Bldg. NE Side

Project: Avoca Central School District

Location:

Lab ID: 2307183-087A

Matrix: PWS

Collection Date: 05/24/23 8:22

Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:54

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 88 Toller Bldg. NW Side

Lab ID: 2307183-088A
Collection Date: 05/24/23 8:22
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 16:58

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 89 Toilet Bldg. SE Side

Lab ID: 2307183-089A
Collection Date: 05/24/23 8:23
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:01

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- II Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 90 Toilet Bldg. SW Side

Lab ID: 2307183-090A
Collection Date: 05/24/23 8:23
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:05

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 91 Toilet Bldg. Bottle Filler

Lab ID: 2307183-091A
Collection Date: 05/24/23 8:24
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:08

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 92 Bus Garage Female RR

Lab ID: 2307183-092A
Collection Date: 05/24/23 8:30
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:12

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 93 Bus Garage Male RR

Lab ID: 2307183-093A
Collection Date: 05/24/23 8:30
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:15

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 94 Bus Garage Sink

Lab ID: 2307183-094A
Collection Date: 05/24/23 8:31
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:19

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim /Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 95 Bus Garage Drink Fountain

Lab ID: 2307183-095A
Collection Date: 05/24/23 8:31
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:30

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 96 Ag Hallway Girls Restroom

Lab ID: 2307183-096A
Collection Date: 05/24/23 6:38
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:33

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 97 Room 209 Restroom

Lab ID: 2307183-097A
Collection Date: 05/24/23 7:31
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:37

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Print/Conf column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Avoca Central School District
Location:
Matrix: PWS

Client Sample ID: 98 Fountain Next to 223

Lab ID: 2307183-098A
Collection Date: 05/24/23 7:45
Date Received: 05/24/23 10:12

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/16/23 17:40

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

Due Date: 2307183
Invoiced Governmental Agency

LSL Central Lab
5854 Butterut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St
City/State: Avoca NY
Phone: 607 522 2221
email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Turnaround Time		Pre-Authorized		Additional Charges						
Normal	14 DAY	Next Day*	2-Day*	3-Day*	7-Day*					
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer mover@qstboxes.org										
Authorization or P.O. #										
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE										
Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers #	size/type	Analyses	Pres. Check	LSL ID#
bag filter POE	5/24/23	5:45	grab	PW	HNO3	1	250ml	Lead		001A
elm office sink		5:47								002A
elm office restroom		5:48								003A
elm office drink fountain		5:49								004A
hs office restroom		5:51								005A
hs office sink		5:52								006A
hs bottle filler		5:53								007A
cafeteria restroom 1		5:55								008A
cafeteria restroom 2		5:56								009A
cafeteria bottle filler		5:57								010A
Custody Transfers										Date
Sampled By: Mike Oyer										Received By:
Relinquished By:										Received By:
Relinquished By:										Rec'd for Lab By: MK
Shipment Method:										Received Intact: Y N
Containers this COC (10)										\$-2423 10:12

Received on ice Yes or No

Sample Temp 20.0

Containers this COC (10)

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY ***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date:

200

Involved Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 315-388-4476
f) 315-388-4061

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

or 585-704-6973

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St
City/State: Avoca NY
Phone: 607 522 2221
email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID Avoca school district lead water test 2023

Turnaround Time	
Normal	Pre-Authorized
14 DAY <input checked="" type="checkbox"/>	Next Day* <input type="checkbox"/> 3-Day* <input type="checkbox"/> 7-Day* <input type="checkbox"/>

Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer
moyer@qstboces.org
Authorization or P.O. #

*Additional Charges may apply

ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
cafeteria drink fountain	5-24-23	5:57	grab	PW	HNO3	1	p250ml	Lead		011A
commons hall restroom		6:00								012A
serving area sink		6:01								013A
washroom sink 1		6:01								014A
washroom sink 2		6:02								015A
washroom hand sink		6:02								016A
washroom prerinse		6:03								017A
kitchen ice maker		6:03								018A
kitchen prep sink		6:04								019A
kitchen skillet filler		6:04								020A

LSL use only:

Received on fee Yes or No

Sample Temp 20.0

Containers this COC (10)

Custody Transfers

Sampled By:	Mike Oyer	Received By:	
Relinquished By:		Received By:	
Relinquished By:		Rec'd for Lab By:	mk
Shipment Method:		Received Intact:	Y N

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

or 585-704-6973

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St
City/State: Avoca NY
Phone: 607 522 2221
email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
kitchen restroom	5-24-2023	6:12	grab	PW	HNO3	1	p250ml	Lead		021A
kitchen hand sink		6:13								022A
small gym drink fountain		6:15								023A
staff room sink 1		6:16								024A
staff room sink 2		6:16								025A
staff room restroom		6:17								026A
132 sink 1		6:19								027A
132 sink 2		6:19								028A
aud lobby fountain 1		6:23								029A
aud lobby fountain 2		6:23								030A

Turnaround Time	Pre-Authorized	Additional Charges
Normal	Next Day* 2-Day* 14 DAY <input checked="" type="checkbox"/> X	3-Day* 7-Day* <input type="checkbox"/>
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer mover@qstbores.org		
Authorization or P.O. #		

Custody Transfers		Date	Time
Sampled By:	Mike Oyer		
Relinquished By:			
Relinquished By:			
Shipment Method:			

Received on Ice	Yes or No
Sample Temp	20.0

Containers this COC	10:12

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

or 585-704-6973

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver st

City/State: avoca ny

Phone: 607 522 2221

email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Turnaround Time	Pre-Authorized	3-Day *	7-Day *	*Additional Charges may apply
Normal	Next Day *	<input type="checkbox"/>	<input type="checkbox"/>	
14 DAY	2-Day *	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer
moyer@gstboces.org
Authorization or P.O. #

ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
aud lobby M rr sink	5-24-2023	6:24	grab	PW	HNO3	1	p250ml	Lead		031A
aud lobby F rr sink 1		6:25								032A
aud lobby F rr sink 2		6:25								033A
men PE restroom		6:30								034A
official room sink		6:30								035A
official room ice maker		6:31								036A
female PE restroom		6:32								037A
ag hall boy restroom		6:37								038A
ag hall bottle filler		6:39 6:36								039A
ag hall girl restroom										040A

LSL use only:

Received on Ice Yes or No

Sample Temp 20.0

Containers this COC 10

Custody Transfers

Sampled By:	Mike Oyer	Received By:	
Relinquished By:		Received By:	
Relinquished By:		Rec'd for Lab By:	MY
Shipment Method:		Received Intact:	Y N
		Date	5-24
		Time	10:12

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***

Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Report Address: Avoca Central School District	
Company:	
Street: 17-29 Oliver St	
City/State: Avoca NY	
Phone: 607 522 2221	
Email: ssaxton@avocacsd.org	
Zip: 14809	
Fax: 607 522 2398	

Client Project ID/Client Site ID Avoca school district lead water test 2023	
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE	

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
142 sink 1	5-24-2023	6:42	grab	PW	HNO3	1	p250ml	Lead		041A
142 sink 2		6:42								042A
138 sink 1		6:45								043A
138 sink 2		6:45								044A
126 restroom		6:50								045A
124 sink 1		6:51								046A
124 ice maker		6:52								047A
122 sink		6:52								048A
124 restroom		6:53								049A
112 restroom		6:54								050A

LSL use only:		Custody Transfers	
Received on fee Yes or No	Sampled By: Mike Oyer	Received By:	Date
Sample Temp 20.0	Relinquished By:	Received By:	Time
Containers this COC (10)	Relinquished By:	Rec'd for Lab By: ML	5-24 10:12
	Shipment Method:	Received Intact: Y N	

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY ***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butterut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St
City/State: Avoca NY
Phone: 607 522 2221
email: ssaxton@avocacsd.org

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Zip: 14809

Fax: 607 522 2398

Turnaround Time		Pre-Authorized		Additional Charges						
Normal	Next Day*	2-Day*	3-Day*	7-Day*	*Additional Charges may apply					
14 DAY	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer mover@gstboces.org										
Authorization or P.O. #										
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE										
Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
106 restroom	5-24-2023	6:57	grab	PW	HNO3	1	p250ml	Lead		051A
106 restroom		6:57								052A
106 sink		6:57								053A
105 restroom		6:58								054A
105 sink		6:58								055A
102 restroom		7:00								056A
102 sink		7:00								057A
eim hall bottlefiller		7:01								058A
103 restroom		7:02								
103 sink		7:08								
LSL use only:										
Received on Ice Yes or No		Sampled By:		Mike Oyer		Custody Transfers		Received By:		Date
Sample Temp 20.0		Relinquished By:						Received By:		Time
Containers this COC (b)		Relinquished By:						Rec'd for Lab By:		
		Shipment Method:						Received Intact: Y N		

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

2307183

Due Date:

200

Invoiced Governmental Agency

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St

City/State: Avoca NY

Phone: 607 522 2221

Email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Turnaround Time		Pre-Authorized		Additional Charges						
Normal	Next Day*	2-Day*	3-Day*	7-Day*	*Additional Charges may apply					
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer moyer@qstboces.org Authorization or P.O. #										
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE										
Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
100 restroom	5-24-2023	7:10	grab	PW	HNO3	1	p250ml	Lead		059A
100 sink		7:10								060A
200 sink		7:22								061A
201 sink		7:23								062A
202 sink		7:24								063A
elm 2nd flr hall bottle fill		7:24								064A
203 restroom		7:25								065A
203 sink		7:25								066A
204 sink		7:26								067A
205 sink		7:26								068A
LSL use only:										
Received on Ice Yes or No						Sampled By: Mike Oyer				
Sample Temp 20.0						Relinquished By:				
Containers this COC (0)						Relinquished By:				
						Rec'd for Lab By: NY				
						Received Intact: Y N				
						Date 5-24-12				
						Time 10:12				

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***

Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver St
City/State: Avoca NY
Phone: 607 522 2221
email: ssaxton@avocacsd.org

Zip: 14809
Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Turnaround Time		Pre-Authorized		Additional Charges						
Normal	14 DAY	Next Day*	2-Day*	3-Day*	7-Day*					
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer mover@qstboces.org										
Authorization or P.O. #										
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE										
Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv Added	Containers #	size/type	Analyses	Pres. Check	LSL ID#
elm hall 2nd staff RR	5-24-2023	7:27	grab	PW	HNO3	1	p250ml	Lead		069A
fountain across rm215		7:28								070A
217 restroom		7:27								071A
bottle fill next to 223		7:35								072A
elevator restroom		7:36								073A
science storage sink		7:39								074A
216 restroom		7:40								075A
216 sink 1		7:40								076A
216 sink 2		7:40								077A
fountain next to 215		7:42								078A
LSL use only:										
Received on Ice Yes or No						Custody Transfers		Date		
Sample Temp 20.0						Received By: Mike Oyer		Time		
Containers this COC 80						Relinquished By:		Date		
Relinquished By:						Received By:		Date		
Shipment Method:						Rec'd for Lab By: MF		Date 5-24-2023		
Received Intact: Y N										

All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY*** Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date: 200
Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab.
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

or 585-704-6973

Report Address:

Avoca Central School District

Company:

Street: 17-29 Oliver st

City/State: avoca ny

Phone: 607 522 2221

email: ssaxton@avocacsd.org

Zip: 14809

Fax: 607 522 2398

Client Project ID/Client Site ID

Avoca school district lead water test 2023

Turnaround Time		Pre-Authorized		Additional Charges						
Normal	14 DAY	Next Day*	2-Day*	3-Day*	7-Day*					
	<input checked="" type="checkbox"/>									
Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer moyer@astiboces.org										
Authorization or P.O. #										
ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE										
Client's Sample Identifications	Sample Date	Sample Time	Type	Containers		Preserv Added	Matrix	Analyses	Pres. Check	LSL ID#
				#	size/type					
bottle fill next to 233	5-24	7:45	grab	1	p250ml	HNO3	PW	Lead		079A
235 sink		7:47								080A
237 sink 1		7:49								081A
237 sink 2		7:49								082A
237 kiln sink		7:49								083A
241 sink		7:50								084A
bottle fill next to 249		7:52								085A
consession stand		8:21								086A
toilet bldg NE side		8:22								087A
toilet bldg NW side		8:22								088A
LSL use only:										
Received on-ice Yes or No										
Sample Temp 20.0										
Containers this COC										
Sampled By: Mike Oyer										
Relinquished By:										
Relinquished By:										
Shipment Method:										
Received Intact: Y N										
Rec'd for Lab By: M										
Date: 5-24										
Time: 10:12										

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY ***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

CHAIN OF CUSTODY RECORD

2307183

Due Date:

200

Invoiced Governmental Agency

LSL Central Lab
5854 Butternut Drive
E. Syracuse, NY 13057
p) 315-445-1105
f) 315-445-1301

LSL North Lab
131 St. Lawrence Ave.
Waddington, N.Y. 13694
p) 315-388-4476
f) 315-388-4061

LSL Finger Lakes Lab
16 N. Main St.
Wayland, NY 14572
p) 585-728-3320
f) 585-728-2711

LSL Midlakes Office
493 S. Main St.
Canandaigua, NY 14424
p) 585-728-3320
f) 585-728-2711
or 585-704-6973

LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

Report Address: Avoca Central School District				Turnaround Time Normal <input type="checkbox"/> Pre-Auth <input type="checkbox"/> 14 DAY <input checked="" type="checkbox"/> 2-Day * <input type="checkbox"/> 3-Day * <input type="checkbox"/> 7-Day * <input type="checkbox"/> *Additional Charges may apply						
Company: Street: 17-29 Oliver St City/State: Avoca NY Phone: 607 522 2221 email: ssaxton@avocacsd.org				Date Needed or Special Instructions: Please fax lab report to NYSDOH (Hornell), email school district and Mike Oyer moyer@gstboces.org Authorization or P.O. #						
Client Project ID/Client Site ID Avoca school district lead water test 2023				ALL SAMPLES MUST BE KEPT COLD AFTER SAMPLING AND DELIVERED TO THE LAB ON ICE						
Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preserv Added	Containers		Analyses	Pres. Check	LSL ID#
						#	size/type			
toilet bldg SE side	5-24-23	8:23	grab	PW	HNO3	1	p250ml	Lead		089A
toilet bldg SW side		8:23								090A
toilet bldg bottle filler		8:24								091A
bus gagarge female RR		8:30								092A
bus gagarge male RR		8:30								093A
bus garage sink		8:31								094A
bus garage bottle fill		8:31								095A
ASHAN WAY		6:38								096A
5-15 RESIDUAL		7:31								097A
Am 209 R.R.		7:45								098A
FOULSHAM NEXT 223										
LSL use only:										
Received on ice Yes or No				Custody Transfers				Date Time		
Sample Temp 20 C				Sampled By: Mike Oyer				Received By:		
Containers this COC (10)				Relinquished By:				Received By:		
				Relinquished By:				Rec'd for Lab By:		
				Shipment Method:				Received Intact: Y N		
								5-24 10:12		

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.



Life Science Laboratories, Inc.

Avoca Central School
17-29 Oliver St.
Avoca, NY 14809

Phone: (607) 566-2221
FAX: (607) 566-2398

Laboratory Analysis Report

Prepared For

Avoca Central School

LSL Project ID: **2309635**

Receive Date/Time: 07/06/23 11:02

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248


LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032


LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:



David J. Prichard, Director of Tech. Services

Date:



A copy of this report was sent to: Mike Oyer: moyer@gstboces.org
Originally Printed: 7/21/23 Hornell DOH

- - LABORATORY ANALYSIS REPORT - -

Avoca Central School Avoca, NY

Sample ID: Avoca Central School LSL Sample ID: 2309635-001
Location: POE Bag Filter
Sampled: 07/06/23 8:30 Sampled By: MO
Sample Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
(1) EPA 200.8, Rev. 5.4 Metals	EPA 200.2			
Please refer to the next page				MT

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** *POE Bag Filter***Project:** Avoca Central School**Location:****Lab ID:** 2309635-001A**Matrix:** PWS**Collection Date:** 07/06/23 8:30**Date Received:** 07/06/23 11:02

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0053 *	mg/L	07/14/23 15:21

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Avoca Central School Avoca, NY

Sample ID: Avoca Central School LSL Sample ID: 2309635-002
Location: Rm 106 Restroom
Sampled: 07/06/23 8:00 Sampled By: MO
Sample Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
(1) EPA 200.8, Rev. 5.4 Metals	EPA 200.2			
Please refer to the next page				MT

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS**Client Sample ID:** *Rm 106 Restroom***Project:** Avoca Central School**Location:****Lab ID:** 2309635-002A**Matrix:** PWS**Collection Date:** 07/06/23 8:00**Date Received:** 07/06/23 11:02

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	07/14/23 15:32

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



LSL Southern Tier Office
24 W. Main St.
Cuba, NY 14727
p) 585-209-4032
Office # 2

200
Invoiced Governmental Agency

[illegible]

Business and receiving hours vary by location. Please call local lab or 585-728-3320 for more info.